



## Outdoor Festival Requirements

- **Tent Structures** shall conform to CAN/ULC-S109 Flame Resistance of "CC-ICT" Reinforced Material (Have a FlameSpread Rating)
- **Portable fire extinguishers;**
  - Be located within the area occupied by each tent structure.
  - Be mounted in a visible location, not on the floor or obstructed, have a current service tag,
  - Be full and functioning with no leaks, damage, corrosion, or clogged nozzles,
  - Have a minimum rating 2A-10BC.
  - Maintenance report must be provided to determine any deficiencies.
  - Maximum travel distance (actual walking distance) for class A extinguisher is 75'.
- **K-Class Extinguishers;**
  - Shall have a current service tag,
  - Be within 75' (25 meters) of all kitchen areas,
  - Tents with more than one deep fryer or large wok shall have their own K-Class extinguisher
- **Propane cylinders;**
  - Milk crate crates or an equivalent shall be used to hold 201b portable propane cylinders,
  - 60-100lb cylinders shall be secured by chain to a secure object (tent post) to help prevent accidental tipping,
  - Compressed gas lines shall be free of splits, cracks or other wear and utilize only approved connecting hardware i.e. crimped connections. NO Vise Grips or other unprofessional adaptations will be allowed.
  - Cylinders shall be less than 10 years old from the original qualification date,
  - Any extra cylinders shall be stored in a well-ventilated, secure area safe from vandals inside a metal cage with ventilation above and beneath,
  - Shall be a minimum of 3' meters from any structure, and no standing grass or combustible should impinge cylinder
- **Hot water Tanks/heaters venting** shall be installed a safe distance from the temporary tent structures,
- **Portable Generators** shall have no obvious disrepair and all stock fittings shall remain intact,
- **Portable gasoline Gerry cans** shall have no obvious disrepair and stock fittings shall remain intact,
- **Surge Protectors, power bars or extension cords** are generally used on a temporary basis only.
- **Storage items** shall not impede exiting.
- **Electrical boxes** must be covered with approved cover.